

Port Washington Elementary School

PWSID OH7950312

Routine Lead and Copper sampling was conducted September 27, 2018. Ten sites were sampled for lead and copper. Our 90th percentile value for lead does not exceed the action level, therefore, there are no lead actions being implemented at this time other than sharing this consumer notice. Location(s) along with the lead and copper value for each location are listed in the table below.

Room Number	Lead Concentration ug/L	Copper Concentration ug/L
108	1	630
112	<1	573
124	<1	635
207	<1	701
220	1	528

Port Washington Elementary School collects and analyzes water from representative spigot taps throughout the building for the presence of lead and copper in the water supply twice per year as required by Ohio EPA. The results of values found are under the required action level prescribed by OEPA.

For More Information Please Contact: Chris Edwards 740-254-4376, visit US EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.